

**CITY OF MADISON HEIGHTS  
COMMUNITY DEVELOPMENT DEPARTMENT  
BUILDING DIVISION  
(248) 583-0831**

## **DECK GUIDELINES**


The following standards are to be followed when constructing a deck or raised patio:

1. All support posts/columns on attached decks shall be set on concrete 42" below grade. Unattached decks must extend below any organic soils to bearing soil. Footings for concrete patios that may be built upon are required to be 8" x 42" with a 4" slab. If there is no intent to build on the patio slab now, or in the future, a 4" x 24" ratwall is recommended.
2. All walking surfaces 30" or more above finished grade require guardrails. All guardrails installed must be a minimum of 36" in height from the top of the deck to the top of the handrail. Guards must be designed so that a 4" ball can not pass through the guard at any point and may not have any ladderable elements..
3. All material in contact with the ground or masonry shall be .6 pressure treated and material used for the remaining structure of the deck shall be pressure treated or rot resistant species.
4. Deck heights shall be no higher than 4" below any threshold or entrance leading into the home.
6. Provide weed control under deck.

Two sets of construction drawings of the deck will be required along with the Building Permit application. Attached worksheets may also be returned with the plan.

**STRUCTURAL REQUIREMENTS**  
**FOR A DECK PERMIT**


1. Type of Material and Size of Lumber \_\_\_\_\_
2. Post Size, Spacing, and Posthole Depth \_\_\_\_\_
3. Deck Size (Show all Dimensions) \_\_\_\_\_
4. Beam Size, Location & Span \_\_\_\_\_
5. Joist Size, Spacing & Span \_\_\_\_\_
6. Method of Support next to House \_\_\_\_\_
7. Height of Deck Above Ground \_\_\_\_\_
8. Steps must have support at bottom.
9. Show height & spacing of railing. \_\_\_\_\_  
(Minimum 36" high/maximum 4" between spindles).
10. Treated lumber **on** or **in** ground shall  
Have a .60 retention.



# RAILING POST-TO-DECK FRAMING

The railing connection is one of the more crucial connections pertaining to safety, and it is often inadequately constructed. In order to provide the required load resistance at the hand rail, the post must not only be fastened to the rim joist, but also tied back into the joist framing. Machine bolts through the post and rim joist alone do not typically meet the performance requirements of the code. The details shown below have been shown through testing to resist the forces called out by the codes.

## SIMPSON SOLUTION



For more information on this application, see technical bulletin T-HD2AGRDR06

## Code Requirements

### When required

- ✓ Guards shall be located along open-sided walking surfaces, porches, balconies or raised floor surfaces more than 30" above the floor or grade below.  
– *IRC 2006, Section R312.1 / IBC 2006, Section 1013.1*

### Height

- ✓ Guards shall be a minimum of 36" tall (IRC) or 42" tall (IBC)  
– *IRC 2006, Section R312.1 / IBC 2006, Section 1013.2*

### Load Resistance

- ✓ Handrail assemblies and guards shall be able to resist a single concentrated load of 200 pounds, applied in any direction at any point along the top (IRC & IBC), and have attachment devices and supporting structure to transfer this loading to appropriate structural elements of the building (IBC only). – *IRC 2006, Table R301.5 / IBC 2006, Section 1607.7.1*

**Selection of products based upon performance and/or suitability for a specific application should be made by a qualified professional.** Simpson recommends that product choice be approved by the local building department before construction begins.



These products are available with a ZMAX® or hot-dipped galvanized finish. Stainless steel connectors are also available for higher exposure environments or applications using certain preservative treated woods. See page 5 for more details.

**DTT2** Deck Post Connectors

The DTT2 is a safe, cost-effective way to attach deck-railing posts to the deck framing. Because the post is tied back into the deck joists, rather than to the rim joist alone, the connection is stronger than typical through-bolt installations and complies with IRC and IBC code requirements regarding handrail and guardrail post connections for decks. The DTT2 also complies with the new IRC requirements for laterally tying the deck to the house. Additionally, the versatile DTT2 is load rated as a holdown for light-duty shearwalls and braced wall panel applications. The DTT2 fastens easily to a single 2x joist or stud using Simpson Strong-Tie® Strong-Drive® SDS screws (*included*) and accepts a 1/2" machine bolt or anchor bolt.

The new DTT2SS is made from stainless steel for applications in higher-exposure environments. Whether it's a deck guardrail post application or the lateral-load connection from the deck to the adjacent structure, the new stainless-steel DTT2 is the best choice for seaside applications or those calling for more corrosive preservative-treated lumber formulations. It fastens to the framing members with stainless-steel Simpson Strong-Tie Strong-Drive SDS wood screws (*included*).

The new DTT2Z-SDS2.5 is our standard DTT2Z packaged with 2 1/2" Simpson Strong-Tie Strong-Drive SDS wood screws instead of the standard 1 1/2" fasteners. These longer screws allow the DTT2Z to achieve a load capacity in excess of 2100 lbs. when used as a holdown on double studs in a shearwall application. The DTT2Z-SDS2.5 is also suitable in deck applications when double 2x members are used for deck joists or blocking.



**MATERIAL:** DTT2Z/DTT2SS—14 gauge

**FINISH:** DTT2Z—ZMAX® coating; DTT2SS—Stainless steel;  
see Corrosion Information, page 18-19.

**INSTALLATION:** Use all specified fasteners. See General Notes.


- A standard cut washer (*refer to General Notes*) must be installed between the nut and the seat.
- Simpson Strong-Tie SDS screws install best with a low speed high torque drill with a 3/8" hex head driver.

**CODES:** See page 20 for Code Reference Key Chart.



**DTT2 installed  
as a lateral connector  
for a deck guardrail post.**

For more information on  
guardrail post connections, see  
technical bulletin T-GRDRLPST.



**Typical Deck-to-House  
Lateral Load Connection**

*These products are available with additional corrosion protection. Additional products on this page may also be available with this option, check with Simpson Strong-Tie for details.*

Model No.	¢	Anchor Diameter	Fasteners	Minimum Wood Member Thickness	Allowable Tension Load				Code Ref.	
					DF/SP		SPF/HF			
					(100)	(160) <sup>1</sup>	(100)	(160) <sup>1</sup>		
DTT2	13/16	1/2	8-SDS 1/4" x 1 1/2"	1 1/2	1825	1825	1440	1800	16, L8, F5	
				3	2000	2145	1440	1835		
DTT2Z-SDS2.5	13/16	1/2	8-SDS 1/4" x 2 1/2"	3	2145	2145	2105	2105	170	

1. The allowable loads have been increased 60% for wind or earthquake loading with no further increase allowed.
2. Load values are valid if the product is flush with the end of the framing member or installed away from the end.
3. The guardrail post illustration above addresses an outward force on the guardrail. An additional DTT2 can be added at the lower bolt to address an inward force.

**DPTZ** Deck Post Tie

The DPTZ Deck Post Tie products are used to attach 2x4 (DPT5Z) or 4x4 (DPT7Z) vertical posts to the side of stringers, rims or other wood members.


**MATERIAL:** 14 gauge

**FINISH:** ZMAX® coating; see Corrosion Information,  
page 18-19.


**INSTALLATION:**

- Use specified HDG fasteners. See General Notes.
- Install in pairs.
- Install with two 3/8" through bolts into side member and 5-10dx1 1/2 to post for DPT5Z or 5-10d for DPT7Z.

*These products are approved for installation with the Strong-Drive SD Structural-Connector screw. See page 30 for the correct substitution and SD screw size.*



**DPT7Z**  
(DPT5Z similar)




**Typical DPT7Z  
Stairway Installation**  
(DPT5Z similar)

# Design for Code Acceptance

6

## Prescriptive Residential Wood Deck Construction Guide

Based on the 2009 International Residential Code



Where applicable, provisions and details contained in this document are based on the *International Residential Code (IRC)* [bracketed text references applicable sections of the *IRC*]. Prescriptive construction methods recommended meet or exceed minimum requirements of the *IRC*. Provisions that are not found in the *IRC* are recommended as good industry practice. Where differences exist between provisions of this document and the *IRC*, provisions of the *IRC* shall apply. This document is not intended to preclude the use of other construction methods or materials. All construction and materials must be approved by the authority having jurisdiction. Every effort has been made to reflect the language and intent of the *IRC*. However, no assurance can be given that designs and construction made in accordance with this document meet the requirements of any particular jurisdiction.

**CONTENTS**

MINIMUM REQUIREMENTS.....	2	PROHIBITED LEDGER ATTACHMENTS .....	12
DECKING REQUIREMENTS.....	3	LEDGER BOARD FASTENERS .....	12
JOIST SIZE.....	3	FREE-STANDING DECKS.....	14
BEAM SIZE & ASSEMBLY REQUIREMENTS .....	5	DECK STABILITY.....	14
DECK FRAMING PLAN.....	6	GUARD REQUIREMENTS .....	15
JOIST-TO-BEAM CONNECTION.....	7	GUARD POST ATTACHMENTS .....	16
JOIST HANGERS .....	7	STAIR REQUIREMENTS.....	17
POST REQUIREMENTS .....	7	STAIR HANDRAIL REQUIREMENTS .....	18
RIM JOIST REQUIREMENTS.....	8	STAIR FOOTING REQUIREMENTS .....	19
FOOTINGS .....	9	STAIR LIGHTING REQUIREMENTS .....	19
LEDGER ATTACHMENT REQUIREMENTS.....	10	FRAMING AT CHIMNEY OR BAY WINDOW .....	19

**MINIMUM REQUIREMENTS**

1. This document applies to single level residential wood decks only.
2. All lumber shall be identified by the grade mark of, or certificate of inspection issued by, an approved lumber grading or inspection bureau or agency ([www.alsc.org](http://www.alsc.org)). All lumber shall be a naturally durable species (such as Redwood or Western Cedars) or be pressure-treated with an approved process and preservative in accordance with American Wood Protection Association standards (such as but not limited to those shown in Table 1) [R317 and R318]. All lumber in contact with the ground shall be approved preservative treated wood suitable for ground contact. [R317.1.2]
3. All nails shall meet the requirements of *ASTM F 1667*. Threaded nails as stated in this document include helical (spiral) and annular (ring-shank) nails. Wood screws shall meet the requirements of *ANSI/ASME B18.6.1*. Bolts and lag screws shall meet the requirements of *ANSI/ASME B18.2.1*.
4. Throughout this document,  $\frac{1}{2}$ " diameter bolts and lag screws are specified for various connections. Edge distance and spacing requirements are based on  $\frac{1}{2}$ " diameter fasteners. If larger (or smaller) fasteners are specified, edge distance and spacing needs to be adjusted.
5. To resist corrosion, the following is required [R317.3]:
  - All screws, bolts, and nails for use with preservative treated wood shall be hot-dipped zinc-coated galvanized steel, stainless steel, silicon bronze, or copper. Fasteners to be hot-dipped galvanized shall meet the requirements of *ASTM A 153, Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*, Class D for fasteners  $\frac{3}{8}$ " diameter and smaller or Class C for fasteners with diameters over  $\frac{3}{8}$ ".

- Fasteners other than nails and timber rivets shall be permitted to be of mechanically deposited zinc-coated steel with coating weights in accordance with *ASTM B 695*, Class 55, minimum.
- All hardware (joist hangers, cast-in-place post anchors, etc.) shall be galvanized or shall be stainless steel. Hardware to be hot-dipped prior to fabrication shall meet *ASTM A 653, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process*, G-185 coating. Hardware to be hot-dipped galvanized after fabrication shall meet *ASTM A123, Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products*.
- Fasteners and connectors exposed to salt water or located within 300 feet of a salt water shoreline shall be stainless steel grade 304 or 316.
- Other coated or non-ferrous fasteners or hardware shall be as approved by the authority having jurisdiction.
- 6. Decks supporting large concentrated loads such as hot tubs are beyond the scope of this document.
- 7. This document does not apply to decks which will experience snow loads, snow drift loads, or sliding snow loads that exceed 40 psf. This document does not address wind or seismic design issues.
- 8. Flashing shall be corrosion-resistant metal [R703.8] of minimum nominal 0.019-inch thickness or approved non-metallic material. Aluminum should not be used in direct contact with lumber treated with preservatives that contain copper such as ACQ, Copper Azole, or ACZA.
- 9. Decks shall not be used or occupied until final inspection and approval is obtained.
- 10. This document is not intended to preclude the use of other construction methods or materials not shown herein.

**Table 1. Common preservative treatments and retention levels (pcf) for sawn lumber in ground contact.<sup>a</sup>**

Species	ACQ-B	ACQ-C	ACQ-D	CA-B	CuN-W
Southern Pine	0.40	0.40	0.40	0.21	0.11
Douglas Fir-Larch	0.40	0.40	NR	0.21	0.11
Hem-Fir	0.40	0.40	0.40	0.21	0.11
Ponderosa Pine	0.40	0.40	0.40	0.21	0.11
Red Pine	0.40	0.40	0.40	0.21	0.11
Spruce-Pine-Fir	NR	0.40	NR	NR	NR
Redwood	NR	NR	NR	NR	NR

<sup>a</sup> Preservatives and retentions listed in Table 1 are based on the American Wood Protection Association (AWPA) *Book of Standards*. NR = Treatments Not Recommended.

## **DECKING REQUIREMENTS**

All decking material shall be composed of dimension lumber (2" nominal thickness) or span rated decking in accordance with the American Lumber Standard Committee *Policy for Evaluation of Recommended Spans for Span Rated Decking Products* (November 5, 2004). Attach decking to each joist with 2-8d threaded nails or 2-#8 screws. Space decking boards approximately  $\frac{1}{8}$ " apart. See Figure 11 for decking connection requirements at the rim joist. Decking may be placed from an angle perpendicular to the joists to an angle of 45 degrees to the joists. Each segment of decking must bear on a minimum of 4 joists (or 4 supports).

Decking not meeting these requirements may be substituted when the product has been approved by the authority having jurisdiction.

## **JOIST SIZE**

The span of a joist is measured from the centerline of bearing at one end of the joist to the centerline of bearing at the other end of the joist and does not include the length of the overhangs. Use Table 2 to determine joist span based on lumber size and joist spacing. See Figure 1 and Figure 2 for joist span types.

**Table 2. Maximum Joist Spans ( $L_J$ )**

Species	Size	Joist Spacing (o.c.)		
		Without Overhangs <sup>1</sup>		With Overhangs up to $L_J/4$ <sup>2</sup>
Southern Pine	2x8	13' - 8"	12' - 5"	10' - 2"
	2x10	17' - 5"	15' - 10"	13' - 1"
	2x12	18' - 0"	18' - 0"	15' - 5"
Douglas Fir-Larch, Hem-Fir, SPF <sup>3</sup>	2x8	12' - 6"	11' - 1"	9' - 1"
	2x10	15' - 8"	13' - 7"	11' - 1"
	2x12	18' - 0"	15' - 9"	12' - 10"
Redwood, Western Cedars, Ponderosa Pine <sup>4</sup> , Red Pine <sup>4</sup>	2x8	11' - 8"	10' - 7"	8' - 8"
	2x10	14' - 11"	13' - 0"	10' - 7"
	2x12	17' - 5"	15' - 1"	12' - 4"

1. Assumes 40 psf live load, 10 psf dead load, L/360 deflection, No. 2 grade, and wet service conditions. See Figure 1B.

2. Assumes 40 psf live load, 10 psf dead load, L/180 cantilever deflection with 220 lb point load, No. 2 grade, and wet service conditions. See Figure 1A and Figure 2.

3. Incising assumed for refractory species including Douglas fir-larch, hem-fir, and spruce-pine-fir.

4. Design values based on northern species with no incising assumed.

Figure 1A. Joist Span – Deck Attached at House and Bearing Over Beam




Figure 1B. Joist Span – Joists Attached at House and to Side of Beam





Figure 2. Joist Span – Free Standing Deck



**BEAM SIZE & ASSEMBLY REQUIREMENTS**

Deck beam spans shall be in accordance with Table 3 and can extend past the post centerline up to  $L_B/4$  as shown in Figure 3. Joists may bear on the beam and extend past the beam centerline up to  $L_J/4$  as shown in Figures 1A and 2, or the joists may attach to the side of the beam with joist hangers as shown in Figure 1B.

Joists shall not frame in from opposite sides of the same beam. See JOIST-TO-BEAM CONNECTION details, Figure 6.

Where multiple 2x members are used, the deck's beam is assembled by attaching the members identified in Table 3 in accordance with Figure 4. [Table R602.3(1)]

**Table 3. Deck Beam Spans ( $L_B$ )<sup>1</sup> for Joists Framing from One Side Only**


Species	Size <sup>4</sup>	Joist Spans ( $L_J$ ) Less Than or Equal to:						
		6'	8'	10'	12'	14'	16'	18'
	<b>2-2x6</b>	7' - 1"	6' - 2"	5' - 6"	5' - 0"	4' - 8"	4' - 4"	4' - 1"
	<b>2-2x8</b>	9' - 2"	7' - 11"	7' - 1"	6' - 6"	6' - 0"	5' - 7"	5' - 3"
	<b>2-2x10</b>	11' - 10"	10' - 3"	9' - 2"	8' - 5"	7' - 9"	7' - 3"	6' - 10"
<b>Southern Pine</b>	<b>2-2x12</b>	13' - 11"	12' - 0"	10' - 9"	9' - 10"	9' - 1"	8' - 6"	8' - 0"
	<b>3-2x6</b>	8' - 7"	7' - 8"	6' - 11"	6' - 3"	5' - 10"	5' - 5"	5' - 2"
	<b>3-2x8</b>	11' - 4"	9' - 11"	8' - 11"	8' - 1"	7' - 6"	7' - 0"	6' - 7"
	<b>3-2x10</b>	14' - 5"	12' - 10"	11' - 6"	10' - 6"	9' - 9"	9' - 1"	8' - 7"
	<b>3-2x12</b>	17' - 5"	15' - 1"	13' - 6"	12' - 4"	11' - 5"	10' - 8"	10' - 1"
<b>Douglas Fir-Larch<sup>2</sup>, Hem-Fir<sup>2</sup>, SPF<sup>2</sup>, Redwood, Western Cedars, Ponderosa Pine<sup>3</sup>, Red Pine<sup>3</sup></b>	<b>3x6 or 2-2x6</b>	5' - 5"	4' - 8"	4' - 2"	3' - 10"	3' - 6"	3' - 1"	2' - 9"
	<b>3x8 or 2-2x8</b>	6' - 10"	5' - 11"	5' - 4"	4' - 10"	4' - 6"	4' - 1"	3' - 8"
	<b>3x10 or 2-2x10</b>	8' - 4"	7' - 3"	6' - 6"	5' - 11"	5' - 6"	5' - 1"	4' - 8"
	<b>3x12 or 2-2x12</b>	9' - 8"	8' - 5"	7' - 6"	6' - 10"	6' - 4"	5' - 11"	5' - 7"
	<b>4x6</b>	6' - 5"	5' - 6"	4' - 11"	4' - 6"	4' - 2"	3' - 11"	3' - 8"
	<b>4x8</b>	8' - 5"	7' - 3"	6' - 6"	5' - 11"	5' - 6"	5' - 2"	4' - 10"
	<b>4x10</b>	9' - 11"	8' - 7"	7' - 8"	7' - 0"	6' - 6"	6' - 1"	5' - 8"
	<b>4x12</b>	11' - 5"	9' - 11"	8' - 10"	8' - 1"	7' - 6"	7' - 0"	6' - 7"
	<b>3-2x6</b>	7' - 4"	6' - 8"	6' - 0"	5' - 6"	5' - 1"	4' - 9"	4' - 6"
	<b>3-2x8</b>	9' - 8"	8' - 6"	7' - 7"	6' - 11"	6' - 5"	6' - 0"	5' - 8"
	<b>3-2x10</b>	12' - 0"	10' - 5"	9' - 4"	8' - 6"	7' - 10"	7' - 4"	6' - 11"
	<b>3-2x12</b>	13' - 11"	12' - 1"	10' - 9"	9' - 10"	9' - 1"	8' - 6"	8' - 1"


1. Assumes 40 psf live load, 10 psf dead load, L/360 simple span beam deflection limit, L/180 cantilever deflection limit, No. 2 grade, and wet service conditions.

2. Incising assumed for refractory species including Douglas fir-larch, hem-fir, and spruce-pine-fir.


3. Design values based on northern species with no incising assumed.

4. Beam depth must be equal to or greater than joist depth if joist hangers are used (see Figure 6, Option 3).

**Figure 3: Beam Span Types**

**Figure 4. Beam Assembly Details****DECK FRAMING PLAN**

A framing plan shows the joist and beam layout; the location of the ledger board, posts, and footings, and the type, size, and spacing of the ledger board fasteners. See Figure 5 for an example of a typical deck framing plan.


**Figure 5. Typical Deck Framing Plan**

## JOIST-TO-BEAM CONNECTION

Each joist shall be attached to the beam as shown in Figure 6. Joists may bear on and overhang past the beam a maximum of  $L/4$ . Use Option 1 or Option 2 to attach the joist to the beam. Option 1 shall only be used if the deck is attached to the house with a ledger (see LEDGER ATTACHMENT REQUIREMENTS) or as shown in Figure 23. Mechanical fasteners or hurricane

clips used as shown in Option 2 must have a minimum capacity of 100 lbs in both uplift and lateral load directions. Joists may also attach to the side of the beam with joist hangers per Option 3. Joists shall not frame in from opposite sides of the same beam. See JOIST HANGERS for more information. Hangers, clips, and mechanical fasteners shall be galvanized or stainless steel (see MINIMUM REQUIREMENTS).

**Figure 6: Joist-to-Beam Detail**



## JOIST HANGERS

Joist hangers, as shown in Figure 7, shall each have a minimum download capacity in accordance with Table 3A. The joist hanger shall be selected from an approved manufacturer's product data based on the dimensions of the joist or header it is carrying. Joist hangers shall be galvanized or stainless steel (see MINIMUM REQUIREMENTS).

Use joist hangers with inside flanges when clearances to the edge of the beam or ledger board dictate. Do not use clip angles or brackets to support joists.


**Table 3A: Joist Hanger Download Capacity**

Joist Size	Minimum Capacity, lbs
2x8	600
2x10	700
2x12	800

## POST REQUIREMENTS


All deck post sizes shall be 6x6 (nominal) or larger, and the maximum height shall be 14'-0" measured to the underside of the beam. Posts shall be centered on footings. Cut ends of posts shall be field treated with an approved preservative (such as copper naphthenate) [R402.1.2]. The beam shall be attached to the post by

**Figure 7: Typical Joist Hangers**




notching the 6x6 as shown in Figure 8 or by providing an approved post cap to connect the beam and post as shown in Figure 10. All 3-ply beams shall be connected to the post by a post cap. All thru-bolts shall have washers under the bolt head and nut. Attachment of the beam to the side of the post without notching is prohibited (see Figure 9).

**Figure 8. Post-to-Beam Attachment Requirements**




**Figure 9. Prohibited Post-to-Beam Attachment Condition**




#### **RIM JOIST REQUIREMENTS**

Attach a continuous rim joist to the ends of joists as shown in Figure 11. Attach decking to the rim joist as shown in Figure 11. For more decking attachment requirements, see DECKING REQUIREMENTS.

**Figure 10. Alternate Approved Post-to-Beam Post Cap Attachment**



**Figure 11. Rim Joist Connection Details**



**FOOTINGS [R403]**

See Figure 12 and Table 4 for footing size, footing thickness, and post attachment options and requirements. All footings shall bear on solid ground and shall be placed at least 12 inches below the undisturbed ground surface or below the frost line, whichever is deeper. Contact the authority having jurisdiction to determine the specified frost line. Bearing conditions shall be verified in the field by the building official prior to placement of concrete. Where the building official determines that in-place soils with an allowable bearing capacity of less than 1,500 psf are likely to be present at the site, the allowable bearing capacity shall be determined by a soils investigation. **DECK FOOTINGS CLOSER THAN 5'-0" TO AN EXISTING EXTERIOR HOUSE WALL MUST BEAR AT THE SAME ELEVATION AS THE FOOTING OF THE EXISTING HOUSE FOUNDATION.**

**Do not construct footings over utility lines or enclosed meters. Contact local utilities (call 811) before digging.**


Pre-manufactured post anchors shall be galvanized. See MINIMUM REQUIREMENTS.

**Table 4. Footing Sizes<sup>1</sup>**

Beam Span, $L_B$	Joist Span $L_J$	Round Footing Diameter	Square Footing Dimension	Footing Thickness <sup>2</sup>
6'	<10'	15"	13"	6"
	<14'	17"	15"	6"
	<18'	20"	18"	7"
8'	<10'	17"	15"	6"
	<14'	20"	18"	8"
	<18'	23"	21"	9"
10'	<10'	19"	17"	7"
	<14'	22"	20"	9"
	<18'	25"	23"	10"
12'	<10'	21"	19"	8"
	<14'	24"	22"	10"
	<18'	28"	26"	11"
14'	<10'	22"	20"	9"
	<14'	26"	24"	11"
	<18'	30"	28"	12"
16'	<10'	24"	22"	9"
	<14'	28"	26"	12"
	<18'	32"	30"	13"
18'	<10'	25"	23"	10"
	<14'	30"	28"	12"
	<18'	34"	32"	14"

1. Assumes 1,500 psf soil bearing capacity.

2. Assumes 2,500 psi compressive strength of concrete. Coordinate footing thickness with post base and anchor requirements.

**Figure 12. Typical Footing Options**

### LEDGER ATTACHMENT REQUIREMENTS [R502.2.2]

**GENERAL:** Attach the ledger board, which shall be equal to or greater than the deck joist depth but less than or equal to the rim joist depth, to the existing exterior wall in accordance with Figure 14 through Figure 16. When attachments are made to the existing house band joist, the band joist shall be capable of supporting the new deck. If this cannot be verified or conditions at the existing house differ from the details herein, then either a free-standing deck or full plan submission is required. See FREE-STANDING DECKS.


**SIDING AND FLASHING:** House siding or the exterior finish system must be removed prior to installation of the ledger board. Approved corrosion resistant flashing is required at any ledger board connection to a wall of wood framed construction (see MINIMUM REQUIREMENTS). See Figure 14 for continuous flashing with drip edge. The threshold shall be carefully flashed and caulked to prevent water intrusion due to splash from the deck or melting snow and ice.

**MANUFACTURED WOOD I-JOIST:** The term “I-Joist” denotes manufactured wood “I” joists (see Figure 13A). Many new homes constructed with wood I-joists


include 1" or thicker engineered wood products (EWP) – such as oriented strand board (OSB) or structural composite lumber (SCL) including laminated veneer lumber (LVL) – as band joists (or rim boards) that can support the attachment of a deck (see Figure 14). However, some older homes might be constructed with band boards that are too thin (less than 1") to support a deck. In such cases, a free-standing deck or a full plan submission is required.




**MANUFACTURED WOOD TRUSS:** A metal plate connected wood truss (MPCWT) is an engineered, prefabricated structural component designed for each specific application. MPCWT's used in residential floors are often installed with a 2x4 lumber “ribbon” at the ends of the trusses (see Figure 13B) to tie the ends of the trusses together. The ribbon board, by itself, is not intended to support the deck ledger and deck. Installing residential decks when the floor system for the house uses MPCWT requires a standard detail provided by the truss designer, a free-standing deck, or a full plan submission. Refer to the WTCA Technical Note – *Attachment of Residential Decks to Wood Truss Floor Systems* for special blocking details and attachment requirements ([www.sbcindustry.com](http://www.sbcindustry.com)).

**Figure 13A. Wood I-Joist Profile**



**Figure 13B. Metal Plate Connected (MPC) Wood Floor Trusses with a 2x4 Lumber “Ribbon” at the Ends of the Trusses**




**Figure 14. General Attachment of Ledger Board to Band Joist or Rim Board****Figure 15. Attachment of Ledger Board to Foundation Wall (Concrete or Solid Masonry)****Figure 16. Attachment of Ledger Board to Foundation Wall (Hollow Masonry)**

### PROHIBITED LEDGER ATTACHMENTS


Attachments to exterior veneers (brick, masonry, stone) and to cantilevered floor overhangs or bay windows are prohibited (see Figures 17 and 18). In such cases the

deck shall be free-standing (see FREE-STANDING DECKS).

**Figure 17. No Attachment to or Through Exterior Veneers (Brick, Masonry, Stone)**



**Figure 18. No Attachment to House Overhang**



### LEDGER BOARD FASTENERS

Only those fasteners noted below are permitted. LEAD ANCHORS ARE PROHIBITED.

#### Deck ledger connection to band joist or rim board.

The connection between a deck ledger and a 2-inch

nominal lumber band joist (1-1/2" actual) or EWP rim board bearing on a sill plate or wall plate shall be constructed with 1/2" lag screws or bolts with washers per Table 5 and Figure 19 (see MINIMUM REQUIREMENTS).

**Table 5. Fastener Spacing for a Southern Pine, Douglas Fir-Larch, or Hem-Fir Deck Ledger and a 2-inch Nominal Solid-Sawn Spruce-Pine-Fir<sup>7,9</sup> Band Joist or EWP Rim Board<sup>6</sup>**  
(Deck Live Load = 40 psf, Deck Dead Load = 10 psf)<sup>3,6</sup>

Joist Span	Rim Board or Band Joist	6'-0" and less	6'-1" to 8'-0"	8'-1" to 10'-0"	10'-1" to 12'-0"	12'-1" to 14'-0"	14'-1" to 16'-0"	16'-1" to 18'-0"
<b>Connection Details</b>	<b>On-Center Spacing of Fasteners<sup>4,5</sup></b>							
1/2" diameter lag screw with 15/32" maximum sheathing <sup>1</sup>	1" EWP <sup>6</sup> 1-1/8" EWP <sup>6</sup> 1-1/2" Lumber <sup>7,9</sup>	24" 28" 30"	18" 21" 23"	14" 16" 18"	12" 14" 15"	10" 12" 13"	9" 10" 11"	8" 9" 10"
1/2" diameter bolt with 15/32" maximum sheathing	1" EWP <sup>6</sup> 1-1/8" EWP <sup>6</sup> 1-1/2" Lumber <sup>7,9</sup>	24" 28" 36"	18" 21" 34"	14" 16" 29"	12" 14" 24"	10" 12" 24"	9" 10" 21"	8" 9" 19"
1/2" diameter bolt with 15/32" maximum sheathing and 1/2" stacked washers <sup>2,8</sup>	1" EWP <sup>6</sup> 1-1/8" EWP <sup>6</sup> 1-1/2" Lumber <sup>7,9</sup>	24" 28" 36"	18" 21" 36"	14" 16" 29"	12" 14" 24"	10" 12" 21"	9" 10" 18"	8" 9" 16"

<sup>1</sup> The tip of the lag screw shall fully extend beyond the inside face of the band joist.

<sup>2</sup> The maximum gap between the face of the ledger board and face of the wall sheathing shall be 1/2".

<sup>3</sup> Ledgers shall be flashed or caulked to prevent water from contacting the house band joist (see Figures 14, 15, and 16).

<sup>4</sup> Lag screws and bolts shall be staggered per Figure 19.

<sup>5</sup> Deck ledgers shall be minimum 2x8 pressure-preserved-treated No.2 grade lumber, or other approved materials as established by standard engineering practice.

<sup>6</sup> When solid-sawn pressure-preserved-treated deck ledgers are attached to engineered wood products (minimum 1" thick wood structural panel band joist or structural composite lumber including laminated veneer lumber), the ledger attachment shall be designed in accordance with accepted engineering practice. Tabulated values based on 300 lbs and 350 lbs for 1" and 1-1/8" EWP rim board, respectively.

<sup>7</sup> A minimum 1"x9 1/2" Douglas fir-larch laminated veneer lumber rim board shall be permitted in lieu of the 2" nominal band joist.

<sup>8</sup> Wood structural panel sheathing, gypsum board sheathing, or foam sheathing not exceeding one inch thickness shall be permitted.


<sup>9</sup> The maximum distance between the face of the ledger board and the face of the band joist shall be one inch.

<sup>9</sup> Fastener spacing also applies to southern pine, Douglas fir-larch, and hem-fir band joists.

**Placement of lag screws or bolts in deck ledgers**  
The lag screws or bolts shall be placed as shown in Figure 19. The lag screws or bolts shall be staggered from the top to the bottom along the horizontal run of

the deck ledger (see Figure 19). Proper installation of lag screws or bolts shall be verified by the authority having jurisdiction.

**Figure 19: Ledger Board Fastener Spacing and Clearances**



#### Thru-Bolts

Thru-bolts shall have a diameter of  $\frac{1}{2}$ ". Pilot holes for thru-bolts shall be  $\frac{17}{32}$ " to  $\frac{9}{16}$ " in diameter. Thru-bolts require washers at the bolt head and nut.

#### Expansion and Adhesive Anchors


Use approved expansion or adhesive anchors when attaching a ledger board to a concrete or solid masonry wall as shown in Figure 15 or a hollow masonry wall with a grouted cell as shown in Figure 16. Expansion and adhesive anchor bolts shall have a diameter of  $\frac{1}{2}$ ".

Minimum spacing and embedment length shall be per the manufacturer's recommendations. All anchors must have washers.

#### Lag Screws

Lag screws shall have a diameter of  $\frac{1}{2}$ " (see MINIMUM REQUIREMENTS). Lag screws may be used only when the field conditions conform to those shown in Figure 14. See Figure 20 for lag screw length and shank requirements. All lag screws shall be installed with washers.

**Figure 20: Lag Screw Requirements**



**Lag screw installation requirements:** Each lag screw shall have pilot holes drilled as follows: 1) Drill a  $\frac{1}{2}$ " diameter hole in the ledger board, 2) Drill a  $\frac{5}{16}$ " diameter hole into the band board of the existing house. DO NOT DRILL A  $\frac{1}{2}$ " DIAMETER HOLE INTO THE BAND BOARD.


The threaded portion of the lag screw shall be inserted into the pilot hole by turning. DO NOT DRIVE LAG SCREWS WITH A HAMMER. Use soap or a wood-compatible lubricant as required to facilitate tightening. Each lag screw shall be thoroughly tightened (snug but not over-tightened to avoid wood damage).

### **FREE-STANDING DECKS**

Decks which are free-standing do not utilize the exterior wall of the existing house to support vertical loads (see Figure 21); instead, an additional beam with posts is provided at or within L/4 of the existing house. THE ASSOCIATED DECK POST FOOTINGS SHALL BE PLACED AT THE SAME ELEVATION AS THE

EXISTING HOUSE FOOTING IF LOCATED CLOSER THAN 5'-0" TO AN EXISTING HOUSE WALL (see Figure 2 and Figure 12). For houses with basements, a cylindrical footing (caisson) is recommended to minimize required excavation at the basement wall. Beam size is determined by Table 3.


**Figure 21. Free-Standing Deck**



### **DECK STABILITY**

Decks greater than 2 feet above grade shall be provided with diagonal bracing.


**Figure 22. Diagonal Bracing Requirements**



**Diagonal Bracing:** Provide diagonal bracing both parallel and perpendicular to the beam at each post as shown in Figure 22. When parallel to the beam, the bracing shall be bolted to the post at one end and beam at the other. When perpendicular to the beam, the bracing shall be bolted to the post at one end and a joist or blocking between joists at the other. When a joist does not align with the bracing location, provide blocking between the adjacent joists. Decks attached to the house as shown in Figure 23A do not require diagonal bracing perpendicular to the house. Diagonal bracing parallel to the house may be omitted at the beam adjacent to the house for a free-standing deck attached as shown in Figure 23.

**Free-standing Deck - Attachment to House:** Attach the deck rim joist to the existing house exterior wall as shown in Figure 23 for a free-standing deck. The wall must be sheathed with minimum  $\frac{3}{8}$ " wood structural panel sheathing. Use lag screws or thru-bolts when fastening to an existing band joist or wall stud; use expansion anchors or epoxy anchors when fastening to

**Figure 23. Attachment of Free-Standing Deck to House for Deck Stability**



#### **GUARD REQUIREMENTS**

All decks greater than 30" above grade are required to have a guard [R312.1] - one example is shown in Figure


concrete or masonry. DO NOT ATTACH TO BRICK VENEERS. VERIFY THIS CONDITION IN THE FIELD PRIOR TO UTILIZING THIS METHOD.

Fasteners shall be 16" on center and staggered in 2 rows for free-standing decks. Flashing over the rim joist is required and must be installed in accordance with the flashing provisions in the LEDGER ATTACHMENT REQUIREMENTS.


#### **Deck Supported by Ledger - Attachment to House:**

Where supported by attachment to an exterior wall (Figures 14, 15, or 16), decks shall be positively anchored to the primary structure and designed for both vertical and lateral loads as applicable [R502.2.2]. The lateral load connection required shall be permitted to be in accordance with Figure 23A. Hold down tension devices shall be provided in not less than two locations per deck, and each device shall have an allowable stress design capacity of not less than 1,500 lb [R502.2.2.3]. See the *Commentary* to this document for additional information on applicability of this provision.

**Figure 23A. Example of a Lateral Load Device for a Deck Attached to a House with a Ledger**



**Figure 24. Example Guard Detail**



24. Other methods and materials may be used for guard construction when approved by the authority having jurisdiction.


**GUARD POST ATTACHMENTS**

Deck guard posts shall be a minimum 4x4 (nominal) with an adjusted bending design value not less than 1,100 psi.


Guard posts for guards which run parallel to the deck joists shall be attached to the outside joist per Figure 25. Guard posts for guards that run perpendicular to the deck

joists shall be attached to the rim joist in accordance with Figure 26. Only hold down anchor models meeting these minimum requirements shall be used. Hold down anchors shall have a minimum allowable tension load of 1,800 pounds for a 36" maximum rail height and be installed in accordance with the manufacturer's instructions.

**Figure 25. Guard Post to Outside Joist Example**



**Figure 26. Guard Post to Rim Joist Example**




## STAIR REQUIREMENTS


Stairs, stair stringers, and stair guards shall meet the requirements shown in Figure 27 through Figure 34 and Table 6 except where amended by the local jurisdiction. All stringers shall be a minimum of 2x12. Stair stringers shall not span more than the dimensions shown in Figure 28. If the stringer span exceeds these dimensions, then a 4x4 post may be provided to support the stringer and shorten its span length. The 4x4 post shall be notched and bolted to the stringer with (2)  $\frac{1}{2}$ " diameter through-bolts with washers per Figure 8. The post shall be centered on a 12" diameter or 10" square, 6" thick footing. The footing shall be constructed as shown in Figure 34 and attached to the post as shown in Figure 12. An intermediate landing may also be provided to shorten

the stringer span (see provisions below). If the total vertical height of a stairway exceeds 12'-0", then an intermediate landing shall be required. All intermediate stair landings must be designed and constructed as a free-standing deck using the details in this document. Stairs shall be a minimum of 36" in width as shown in Figure 33 [R311.7]. If only cut stringers are used, a minimum of three are required. For stairs greater than 36" in width, a combination of cut and solid stringers can be used, but shall be placed at a maximum spacing of 18" on center (see Figure 29). The width of each landing shall not be less than the width of the stairway served. Every landing shall have a minimum dimension of 36" measured in the direction of travel and no less than the width of the stairway served [R311.7].

**Figure 27. Tread and Riser Detail**




**Figure 28. Stair Stringer Requirements**



**Figure 29. Tread Connection Requirements**

Attachment per tread at each stringer or ledger:  
 2x\_ or 5/4 treads - (2)8d threaded nails or (2)#8 screws  $\geq 2\frac{1}{2}$ " long  
 3x treads - (2)16d threaded nails or (2)#8 screws  $\geq 3\frac{1}{2}$ " long



**Table 6. Minimum Tread Size for Cut and Solid Stringers<sup>1</sup>**

Species	Cut Stringer	Solid Stringer
Southern Pine	2x4 or 5/4	2x6
Douglas Fir Larch, Hem-Fir, SPF <sup>2</sup>	2x4 or 5/4	2x8 or 3x4
Redwood, Western Cedars, Ponderosa Pine <sup>3</sup> , Red Pine <sup>3</sup>	2x4 or 5/4	2x10 or 3x4

1. Assumes 300 lb concentrated load, L/288 deflection limit, No. 2 grade, and wet service conditions.
2. Incising assumed for refractory species including Douglas fir-larch, hem-fir, and spruce-pine-fir.
3. Design values based on northern species with no incising assumed.

Figure 30. Stair Guard Requirements





Figure 31. Stair Stringer Attachment Detail



### STAIR HANDRAIL REQUIREMENTS

All stairs with 4 or more risers shall have a handrail on at least one side (see Figure 32A) [R311.7.7]. The handrail height measured vertically from the sloped plane adjoining the tread nosing shall be not less than 34 inches and not more than 38 inches (see Figure 30) [R311.7.7.1]. Handrails shall be graspable and shall be composed of decay-resistant and/or corrosion resistant material. Handrails shall be Type I, Type II, or provide equivalent graspability (see Figure 32B). Type I shall have a perimeter dimension of at least 4" and not greater

than 6-1/4". Type II rails with a perimeter greater than 6-1/4" shall provide a graspable finger recess area on both sides of the profile [R311.7.7.3]. All shapes shall have a smooth surface with no sharp corners. Handrails shall run continuously from a point directly over the lowest riser to a point directly over the highest riser and shall return to the guard at each end (see Figure 33). Handrails may be interrupted by guard posts at a turn in the stair [R311.7.7.2].

Figure 32A. Handrail Mounting Examples






Figure 32B. Handrail Grip Size



### STAIR FOOTING REQUIREMENTS [R403]

Where the stairway meets grade, attach the stringers to the stair guard posts as shown in Figure 34. Posts shall bear on footings. All footings shall bear on solid ground and shall be placed at least 12 inches below the undisturbed ground surface or below the frost line, whichever is deeper (see Figure 34). Stringers shall bear on a 2x4 bearing block attached to the post as shown. Stringers shall not bear on new or existing concrete pads or patios that are not founded below this depth. When guards are not required (see GUARD

**Figure 33. Miscellaneous Stair Requirements**




REQUIREMENTS), posts may terminate below the bottom tread elevation. Bolts are only required if a guard post is required.

### STAIR LIGHTING REQUIREMENTS [R303.6]

Stairways shall have a light source located at the top landing such that all stairs and landings are illuminated. The light switch shall be operated from inside the house. However, motion detected or timed switches are acceptable.

**Figure 34. Stair Footing Detail**



### FRAMING AT CHIMNEY OR BAY WINDOW

All members at a chimney or bay window shall be framed in accordance with Figure 35. Headers may span a maximum of 6'-0". When a chimney or bay window is wider than 6'-0", one or more 6x6 posts may be added to reduce header spans to less than 6'-0". In such cases, the post footing must meet the requirements in the FOOTINGS section. Headers with a span length greater than 6'-0" require a plan submission. Headers shall be located no more than 3'-0" from the end of the trimmer joist.



Triple trimmer joists are required on each side of the header if joist spacing is 12" or 16" o.c. or if the trimmer joist span exceeds 8'-6"; otherwise, double trimmer joists are permitted. Trimmer joists may bear on the beam and extend past the beam centerline up to  $L_{J/4}$  as shown in Figures 1A and 2, or the trimmer joist may attach to the side of the beam with joist hangers as shown in Figure

1B. Joist hangers shall each have a minimum download capacity in accordance with Table 7. Bolts or lag screws used to attach the hanger to the ledger shall fully extend through the ledger into the 2-inch nominal lumber band joist (1-1/2" actual) or EWP rim board. Otherwise a freestanding deck is required.

**Table 7. Trimmer Joist Hanger Download Capacity**

Joist Size	Minimum Capacity, lbs
2x8	1050
2x10	1380
2x12	1500

Figure 35: Detail for Framing Around a Chimney or Bay Window



**American  
Wood  
Council**

*Traditional and Engineered Wood Products*



It is intended that this document be used in conjunction with competent design, accurate fabrication, and adequate supervision of construction. While every effort has been made to insure the accuracy of the information presented, the American Forest & Paper Association and its members do not assume responsibility for errors or omissions in the document, nor for designs, plans, or construction prepared from it. Those using this document assume all liability arising from its use.

Copyright © 2007, 2009, 2010  
American Forest & Paper Association, Inc.

01-10